


Općenito

Ova je informacija u prvom redu namijenjena korisnicima uređaja AB 30/60. Pretpostavljamo da su uređaj te eventualne dodatne ventilacijske komponente instalirale i pustile u rad stručne osobe. Isto tako pretpostavljamo da je poznato koji su ventilacijski uređaji odnosno dodatne komponente ugrađeni te gdje su i kako priključeni.

AB 30/60 je odsisni uređaj koji se ugrađuje u funkcionalne prostore poput kuhinje, kupaonice i WC-a vašeg stana ili kuće. Ti će uređaji brinuti o izbacivanju istrošenog i vlagom opterećenog zraka van.



Sljedeći se navodi odnose na ventilator s dodatnim modulom za vrijeme naknadnog rada i sklopkom (uključeno/isključeno) ili povezan sa sklopkom za svjetlo.

Rukovanje i funkcija

Budući da se u vašim stambenim prostorima nalaze uređaji s povratom topline, ti odsisni uređaji rade samo prema potrebi.

Uključivanje i isključivanje uređaja

Aktiviranjem sklopke ili sklopke za svjetlo uređaj se uključuje odnosno ponovno isključuje.



Protok zraka

AB 30/60 može po izboru odvoditi 30 ili 60 m³/h. Ta je vrijednost izračunata u ventilacijskom konceptu. Na pitanja o tome mogu vam odgovoriti instalacijska tvrtka, arhitektonski ili projektni ured.

Odgoda uključivanja i naknadni rad, moguće s opcionalno dostupnim dodatnim modulom

Ako je odgoda uključivanja aktivirana, ventilator se pokreće s odgodom uključivanja od 120 sekundi nakon aktiviranja sklopke. Pri naknadnom radu ventilator nakon isključivanja nastavlja raditi još 6 ili 15 minuta.

Zamjena filtra

U razmaku od približno 3 mjeseca filteri bi se trebali očistiti. U tu svrhu skinite pokrov unutarnje blende, izvadite filter i operite ga u perilici posuđa ili vodom i sredstvom za pranje. Suhi filter zatim ponovno umetnite u nosač okvira filtra i vratite pokrov unutarnje blende u položaj „otvoreno”. Naši filteri koji se mogu regenerirati bez problema se mogu čistiti 4-5 puta prije nego što ih treba zamijeniti novima.

Stavljanje uređaja izvan pogona

Ako se uređaji na dulje vrijeme isključe, unutarnje blende treba zatvoriti, a filtre izvaditi. Pri stankama duljima od 6 mjeseci sve uređaje trebale bi servisirati stručne osobe.


Vaš LUNOS tim

General

This information is primarily intended for the user of the AB 30/60. We assume that the devices and any additional ventilation components have been installed and commissioned by a specialist. We also assume that it is known which ventilation units or additional components have been installed and where and how they are connected.

The AB 30/60 is an exhaust air unit that has been installed in the functional rooms such as the kitchen, bathroom and WC of your flat or house. These units will be responsible for removing stale air and air contaminated with moisture to the outside.

The following versions refer to the fan with additional time delay module and a switch (on/off) or coupled via the light switch.



Operation and function

Since there are units with heat recovery in your living spaces, these exhaust air units are only in operation when required.

Switching the device on/off

The unit is switched on and off by pressing the switch or light switch.



Volume flow

The AB 30/60 can discharge either 30 or 60 m³/h. This value was calculated in the ventilation concept. The installation company, architectural or planning office can answer any questions you may have.

Switch-on delay and overrun, possible with an optionally available module

If the switch-on delay is activated, the fan starts with a switch-on delay of 120 seconds after the switch is pressed. With run-on, the fan continues to run for another 6 or 15 minutes after being switched off.

Filter change

The filters should be cleaned at intervals of approx. 3 months. To do this, remove the cover of the inner screen, take out the filter and clean it in the dishwasher or with water and detergent. You can then put the dry filter back into the filter frame holder and snap the cover of the inner screen back into the "open" position. Our regenerable filters can easily be cleaned 4-5 times before they should be replaced.

Shutting down the devices

If the devices are to be shut down for a longer period of time, close the inner screens and remove all filters. If the devices are to be shut down for more than 6 months, please have all devices professionally serviced.

Your LUNOS team